

Olsson Associates  
Consulting Engineers  
1111 Lincoln Mall  
Lincoln, Nebraska  
January 22, 2007

**ADDENDUM NO. 5**

**Densmore Park Backstop Replacement - 2006  
Lincoln Parks and Recreation  
Specification No. 07-003  
OA Project No. 2006-1639**

**TO ALL WHO HAVE RECEIVED PLANS AND SPECIFICATIONS FOR THE  
REFERENCED PROJECT.**

**SCOPE**

This Addendum covers the following additions, modifications, and clarifications to the Drawings and Specifications for this project.

1. Refer to ADDENDUM #3, FIGURE F-1.
  - a. Add the following note and detail: "Tension bands shall be suitable for connecting horizontal rails to vertical backstop posts at all locations when horizontal rails are more than 16 ft. above ground level. When less than 16ft. above ground level, rails shall be connected using rigid line rail compression clamps similar to the photograph shown on this Addendum #5."



**Each Bidder must acknowledge receipt of all addenda in the space provided on the Proposal form.**